



**Bureau Veritas E&E
Product Services GmbH**
Businesspark A96
86842 Türkheim
Germany
+ 49 (0) 8245 96810-0
cps-tuerkheim@de.bureauveritas.com

Certificate of compliance

Applicant: SolarEdge Technologies Ltd.
Abba Eban 1a
Hertzlia 46725
Israel

Product: Disconnection device for PV generators

Model: Safe DC disconnect mechanism

Use in accordance with regulations:

Disconnection between a solar inverter and a photovoltaic generator

Applied rules and standards :

In dependence on

IEC 60947-3:1999 + Corrigendum:1999 + A1:2001 + Corrigendum 1:2001 + A2:2005
DIN EN 60947-3; VDE 0660-107:2006-03

"Low-voltage switchgear and controlgear - Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units"

and

IEC 60364-7-712:2002-05
DIN VDE 0100-712:2006-06

"Electrical Installations of Buildings - Part 7-712: Requirements for Special Installations or Locations - Solar Photovoltaic (PV) Power Supply Systems"

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate of valid safety specifications for the specified use in accordance with regulations.

Report number: 10TH0432-IEC60947
Certificate nummer: 10-120
Date of issue: 2010-09-16 **Valid until:** 2013-09-16

Achim Hänchen
CERTIFICATION